



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date

5/7/25

PRODUCT LINE TEST

Test Location Information

Name	FID 24742
Address	3204 Monroe St
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:40am	72	0	0.0037	0	0
11:55a	71	-1	0.0037	.0037	.0148
12:10p	70	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:25p	86	0	0.0037	0	0
12:40p	86	0	0.0037	0	0
12:55p	86	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

Date 5/7/25

PRODUCT LINE TEST

Test Location Information

Name	FID 24742
Address	3204 Monroe St
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Regular plug was hard to access, went through the filter.
Regular STP ball valve did not isolate line. Used silver bullet plug to isolate.
Premium plug and ball valve were in good working condition.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 