

5296 Breakers Way, Carmel, IN 46033

	www.tanksdata.com
\boxtimes	tanksdata@gmail.com
3	(317)-300-6065

D	a	t	е

5/7/25

LIQUID SENSOR FUNCTIONALITY	TESTING
-----------------------------	----------------

Facility Name: Marathon					Owner:	Owner:						
Address: 3204 Monroe St					Address:	Address:						
City, State, Zip Code: La	City, State	City, State, Zip Code:										
Facility I.D. #:	24742				Phone #:							
This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.												
Sensor Location	STP 1		STP 2									
Product Stored	Regular		Premium									
Type of Sensor	Non-Discri	•	Non-Discri	•			•				_	
Test Liquid	Water	•	Water	•			•			. [_	
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	Yes	•	Yes	•			•				•	
Is the sensor alarm circuit operational?	Yes	•	Yes	•			•				•	
Has sensor been inspected and in good operating condition?	Yes	•	Yes	•			•			<u> </u>	•	
When placed in the test liquid, does the sensor trigger an alarm?	Yes	•	Yes	•			•				•	
When an alarm is triggered, is the sensor properly identified on the ATG console?	Yes	•	Yes	•			4				•	
Any "No" answers indicates the sensor fails the test.												
Test Results	Pass	•	Pass	•			•				lacksquare	
Comment												
Tester's Name : Josh Rider Tester's Signature :												