

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 24742
Address	3204 Monroe St
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	31	25	240 ml	189ml	3 sec	Pass
2	Premium	27	26	240 ml	189ml	2 sec	Pass
3					189ml		.
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :

