

MAES MART
3204 MONROE ST
LAPORTE IN 46350

JUN 13, 2025 4:54 PM

CSLD TEST RESULTS

JUN 13, 2025 4:54 PM

T 1:RNL
PROBE SERIAL NUM 496196

0.2 GAL/HR TEST
PER: JUN 13, 2025 PASS

T 3:PNL
PROBE SERIAL NUM 625407

0.2 GAL/HR TEST
PER: JUN 13, 2025 PASS

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

JUN 13, 2025 4:54 PM

LIQUID STATUS

JUN 13, 2025 4:54 PM

L 1:RUL STP
SENSOR NORMAL

L 2:PUL STP
SENSOR NORMAL

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

JUN 13, 2025 4:54 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 496196

NO TEST DATA AVAILABLE

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

JUN 13, 2025 4:54 PM

LEAK TEST REPORT

T 3:PNL
PROBE SERIAL NUM 625407

NO TEST DATA AVAILABLE

* * * * * END * * * * *