

MAES MART
3204 MONROE ST
LAPORTE IN 46350

MAY 11, 2025 8:20 PM

FUEL MANAGEMENT REPORT

T 1:RNL

DAYS FUEL REMAINING: 1.8
INVENTORY : 5662 GAL
95% ULLAGE: 3852 GAL

T 3:PNL

DAYS FUEL REMAINING: 5.7
INVENTORY : 2910 GAL
95% ULLAGE: 6605 GAL

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

MAY 11, 2025 8:20 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 496196

NO TEST DATA AVAILABLE

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

MAY 11, 2025 8:20 PM

CSLD TEST RESULTS

- - - - -
MAY 11, 2025 8:20 PM

T 1:RNL
PROBE SERIAL NUM 496196

0.2 GAL/HR TEST
PER: MAY 11, 2025 PASS

T 3:PNL
PROBE SERIAL NUM 625407

0.2 GAL/HR TEST
PER: MAY 11, 2025 PASS

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

MAY 11, 2025 8:20 PM

LIQUID STATUS

- - - - -
MAY 11, 2025 8:20 PM

L 1:RUL STP
SENSOR NORMAL

L 2:PUL STP
SENSOR NORMAL

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

MAY 11, 2025 8:20 PM

LEAK TEST REPORT

T 3:PNL
PROBE SERIAL NUM 625407

NO TEST DATA AVAILABLE

* * * * * END * * * * *