

OVERFILL PREVENTION VERIFICATION (OPV) AUTO SHUT-OFF, BALL FLOAT DATA SHEET

DATE AND TIME	2/22/23 - 11:00 PM
WEATHER	30 Rainy
COLLECT/INVOICE	Collected
CLIENT E-MAIL	

Testing	Company	Information

Test Location Information		Certifications	Name	Midwest Tank Testing
PC # and WO #	PC # and WO #		Address	316 W. Indiana Ave.
Name and FID #	Phillips 66 - FID 18402	ICC: 10221928	City/State/Zip	Chesterton, IN 46304
Address 3301 Portage Ave.		Indiana: UC 110386	Phone	800-975-1436
City/State/Zip	South Bend, IN 46628	Technician Information		
Contact			Name	Chris Zell
Phone			Email	support@midwesttanktesting.com

OVERFILL PREVENTION VERIFICATION (OPV) INSPECTION - AUTOMATIC SHUT-OFF DEVICE AND BALL FLOAT VALVE

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures								dures.	
•	Overfill Prevention Device Brand								
F	Tank #	1	2	3					
lī	Product Stored	Regular	Mid-grade	Premium					

Product Stored	Regular	Mid-grade	Premium			
Tank Volume (gallons)	12k	8k	6k			
Tank Diameter (inches)	96	96	96			
Calculated 90% Level (inches)	81	81	81			
Calculated 95% Level (inches)	86	86	86			
Type (Automatic Shutoff Davice/Poll						

Type (Automatic Shutoff Device/Ball Float Valve)	BFV	BFV	BFV

AUTOMATIC SHUTOFF DEVICE INSPECTION	NC
-------------------------------------	----

Measured Shutoff Level (inches)				
Drop tube removed from tank? (Yes/No)				
2. Drop tube and float mechanisms free of debris? (Yes/No)				
3. Float moves freely without binding and poppet moves into flow path? (Yes/No)				

3. Float moves freely without binding and
poppet moves into flow path? (Yes/No)
4. Bypass valve in the drep tube open

4. Bypass valve in the drop tube open
and free of blockage (if present)?
(Yes/No/Not Present)

5.	Flapper adjusted to shut off flow at	
95	% capacity?* (Yes/No)	

BALL FLOAT VALVE INSPECTION (If a ball float is found to fail the inspection, another method of overfill must be used.)

Is ball float valve present?	Unknown	Unknown	Unknown			
Is ball punched thru disabling valve?	Unknown	Unknown	Unknown			
Is ball float valve completely removed?	Unknown	Unknown	Unknown			
Measured Float Level (inches)						
1. Tank top fittings vapor tight and leak free? (Yes/No)						
2. Ball float cage free of debris? (Yes/No)						
Ball free of holes and cracks and moves freely in cage? (Yes/No)						
4. Vent hole in pipe open and near top of tank? (Yes/No)						
5. Ball float pipe proper length to restrict flow at 90% capacity?** (Yes/No)						

^{*} Use Manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results (Pass/Fail)	Fail	Fail	Fail

Comments:When I moved the ATG fuel float to 90 it did not trigger an audible alarm. I could not remove the adapters to verify BFV.

^{*} Use Manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

A "No" to any item in Lines 1-5 indicates a test failure.