

 EZY CHEK SYSTEMS LEAK DETECTOR TEST AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W. Indiana Ave. Chesterton, IN 46304 REVISION 8/21/2019				DATE AND TIME		2/22/23 - 11:00 PM		
				WEATHER		30 Rainy		
				COLLECT/INVOICE		Collected		
				CLIENT EMAIL		-		
				Testing Company Information				
Test Location Information				Certifications		Name		Midwest Tank Testing
PC # and WO #				Estabrooks: 82-1906		Address		316 W. Indiana Ave.
Name and FID #		Phillips 66 - FID 18402		ICC: 10221928		City/State/Zip		Chesterton, IN 46304
Address		3301 Portage Ave.		Indiana: UC 110386		Phone		800-975-1436
City/State/Zip		South Bend, IN 46628		CP/STI: 16655		Technician Information		
Contact				UC111023		Name		Chris Zell
Phone						Email		support@midwesttanktesting.com
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #	PRODUCT			MODEL		SERIAL # (If Legible)		
1	Regular			FX1V		N/A		
2	Mid-grade			FePetro		N/A		
3	Premium			FX1V		N/A		
4								
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results	
1	Regular	32	31	500	189ml	3	Pass	
2	Mid-grade	27	26	850	189ml	2	Pass	
3	Premium	26	25	770	189ml	4	Pass	
4					189ml			
5					189ml			
6					189ml			
7					189ml			
8					189 ml			
COMMENTS/RECOMMENDATIONS:								