

**HYDROSTATIC SPILL BUCKET
 (HSB) INTEGRITY TEST
 DATA SHEET**

DATE AND TIME	7/7/21 - 0930/1200
WEATHER	77 - Sunny
COLLECT/INVOICE	Collected
CLIENT E-MAIL	

Test Location Information	
PC # and WO #	
Name and FID #	Phillips 66 - FID # 18402
Address	3301 Portage Ave.
City/State/Zip	South Bend, IN 46628
Contact	
Phone	

Testing Company Information	
Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436
Technician Information	
Name	Adam Case
Cert #	27-1160

HYDROSTATIC SPILL BUCKET (HSB) INTEGRITY TEST

This procedure is to test the leak integrity of single and double walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method.

Tank #	1	2	3					
Product Stored	Regular	Mid-Grade	Premium					
Manufacturer								
Construction (Single Wall/Double Wall)	Single	Single	Single					
Test Type (Single Wall/Double Wall)	HYDROST. SINGLE WALL	HYDROST. SINGLE WALL	HYDROST. SINGLE WALL					
Spill Bucket Type (Product/Vapor)	Product	Product	Product					
Liquid and Debris Removed From Spill Bucket? (All liquids & debris must be disposed of properly) (Yes/No)	Yes	Yes	Yes					
Visual Inspection (No cracks, loose parts or separation of bucket from the fill pipe) If fail, omit hydrostatic test. (Pass/Fail)	Pass	Pass	Pass					
Tank Riser Cap Included In Test? (Yes, No, N/A)	Yes	Yes	Yes					
Drain Valve Included In Test? (Yes, No, N/A)	Yes	Yes	Yes					
Starting Water Level (inches)	12	12	12					
Test Start Time	10:00 AM	10:00 AM	10:00 AM					
Ending Water Level (inches)	12	12	12					
Test End Time	11:00 AM	11:00 AM	11:00 AM					
Test Period (minutes)	60	60	60					
Water Level Change (inches)	0	0	0					

Pass/Fail Criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8"

Test Results (Pass/Fail)	Pass	Pass	Pass					
--------------------------	------	------	------	--	--	--	--	--

Comments: