

000
Tank Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 18402

Contact Number

Facility Name PHILLIPS 66

Contact email

Address 3301 Postage Ave, South Bend,

Date of Inspection 09/05/24

Operator on Duty Name

W 46628

Name of the Person Conducting Inspection

AKSHIT

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Release Detection Method

Make and Model

Release Detection
☒ ATG
VR 745 350

☐ SIR

☐ IC

☐ Other

Does it have paper?

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Is it in Alarm mode?

☒ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

☐ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Spill Buckets

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Piping/STP Sumps

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

Under Dispenser Contaminants (UDC)

☐ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

☐ Yes

☒ No

Operator Notified

☒ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

Date

tankdata@gmail.com

www.tankdata.com