

PORTAGE ONE STOP5308
3301 PORTAGE AVE.
SOUTH BEND IN.46628
574-277-8144

JUN 3, 2024 4:03 PM

CSLD TEST RESULTS

JUN 3, 2024 4:03 PM

T 1:UNL E
PROBE SERIAL NUM 363160

0.2 GAL/HR TEST
PER: JUN 3, 2024 PASS

T 2:UNL W
PROBE SERIAL NUM 363161

0.2 GAL/HR TEST
PER: JUN 3, 2024 PASS

T 3:PREMIUM
PROBE SERIAL NUM 855722

0.2 GAL/HR TEST
PER: JUN 3, 2024 PASS

* * * * * END * * * * *

PORTAGE ONE STOP5308
3301 PORTAGE AVE.
SOUTH BEND IN.46628
574-277-8144

JUN 3, 2024 4:04 PM

LEAK TEST REPORT

T 1:UNL E
PROBE SERIAL NUM 363160

TEST STARTING TIME:
MAY 5, 2015 12:00 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4129.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

PORTAGE ONE STOP5308
3301 PORTAGE AVE.
SOUTH BEND IN.46628
574-277-8144

JUN 3, 2024 4:04 PM

LEAK TEST REPORT

T 2:UNL W
PROBE SERIAL NUM 363161

TEST STARTING TIME:
MAY 5, 2015 12:00 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2163.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

PORTAGE ONE STOP5308
3301 PORTAGE AVE.
SOUTH BEND IN.46628
574-277-8144

JUN 3, 2024 4:04 PM

LEAK TEST REPORT

T 3:PREMIUM
PROBE SERIAL NUM 855722

TEST STARTING TIME:
MAY 5, 2015 12:00 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 0.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW
INVALID FUEL LEVEL

* * * * * END * * * * *