

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 182402
 Facility Name Blue Ridge
 Address 3301 Postage Rd
 Operator on Duty Name Sarah Reed Ins-246628

Contact Number
 Contact email
 Date of Inspection 03/21/25
 Name of the Person Conducting Inspection ANKIT

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Registration/Notification Form

Is Registration current with correct owner, operator etc.

☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ CIM ☐ SIR

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal
 Necessary Monthly Printout Taken

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?
 Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Pipeline/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS
 FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com