

ESTABROOK PRECISION LINE TEST

Facility Name: PHILLIPS 66

Facility Address: 3301 PORTAGE AVENUE SOUTH BEND IN ...

Facility ID: 18402

Test Date: 03/19/2025

Technician Name: Luke huizenga

Technician Cert #: 071399

Applied Pressure: 50 PSI

#1 Product Type: Regular					
TIME	DATA	-/+	GPL	RES	GPH
12:00	30	0	0.0037	0.0000	0.0000
12:15	30	0	0.0037	0.0000	0.0000
12:30	30	0	0.0037	0.0000	0.0000
FINAL RESULT: PASS					

#2 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#3 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#4 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#5 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#6 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

DATA = Numbered line increments on site glass.

-/+ = Change from previous 15-minute reading.

GPL = Gallons per Line on site glass.

RES = Result. Gain or loss of lines X .0037

GPH = Gallons per Hour. RES X 4

PASS Requirements:

3 consecutive readings within .020 GPH of each other
and final reading less than .050 GPH.

Technician Name: Luke huizenga

Dispatch # 413137

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19