

Tanks Data		30 DAYS WALK THROUGH INSPECTION			
UST Facility ID (FID) #	16625	Contact Number			
Facility Name	40000	Contact email			
Address	8498 US-6 #35 La Porte 46350	Date of Inspection	6/19/2022		
Operator on Duty Name	Linky	Name of the Person Conducting Inspection	V. J. EVANS		
Operator Training current		Operator Training			
☐ Yes		☐ No		☐ Operator Notified	
Is Registration current with correct owner, operator etc.		Registration/Notification Form		☐ Yes ☐ No	
Release Detection Method		Release Detection			
Make and Model		☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other			
Does it have paper?		☒ Yes ☐ No			
Is it in Alarm mode?		☒ Yes ☐ No			
Interstitial Monitoring Sensor Status Normal		☒ Yes ☐ No			
Necessary Monthly Printout Taken		☒ Yes ☐ No			
Spill Buckets		Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?		☒ Yes ☐ No		☒ Operator Notified ☐ No	
Are the Spill Bucket in good condition and free of damage/cracks		☒ Yes ☐ No		☒ Operator Notified ☐ No	
Is Fill pipe cap tight and fill pipe free from any obstruction?		Fill Ports		Operator Notified	
☒ Yes ☐ No		☒ Yes ☐ No		☐ Yes ☐ No	
Are Sumps Clean and free from water, debris, product etc?		Piping/STP Sumps		Operator Notified	
☒ Yes ☐ No		☒ Yes ☐ No		☒ Yes ☐ No	
Are UDCs clean and free from water, debris, product etc?		Under Dispenser Containers (UDC)		Operator Notified	
☒ Yes ☐ No		☒ Yes ☐ No		☒ Yes ☐ No	
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.					
Operator on Duty Name		Signature		Date	
317-645-0215				www.tanksdata.com	