

KINGSFORD EXPO
8498 S US 6
HAMLET, IN 46532

OCT 14, 2024 5:06 PM

CSLD TEST RESULTS

OCT 14, 2024 5:06 PM

T 1:UNL
PROBE SERIAL NUM 818693

0.2 GAL/HR TEST
PER: OCT 14, 2024 PASS

T 2:PRM
PROBE SERIAL NUM 048568

0.2 GAL/HR TEST
PER: OCT 14, 2024 PASS

* * * * * END * * * * *

KINGSFORD EXPO
8498 S US 6
HAMLET, IN 46532

OCT 14, 2024 5:06 PM

LIQUID STATUS

OCT 14, 2024 5:06 PM

NONE

* * * * * END * * * * *

KINGSFORD EXPO
8498 S US 6
HAMLET, IN 46532

OCT 14, 2024 5:06 PM

LEAK TEST REPORT

T 1:UNL
PROBE SERIAL NUM 818593

NO TEST DATA AVAILABLE

* * * * * END * * * * *

KINGSFORD EXPO
8498 S US 6
HAMLET, IN 46532

OCT 14, 2024 5:06 PM

LEAK TEST REPORT

T 2:PRM
PROBE SERIAL NUM 048568

NO TEST DATA AVAILABLE

* * * * * END * * * * *