



5296 Breakers Way, Carmel, IN 46033

Date 11/25/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16625
Address	8498 S US 6
City	Hamlet, IN 46532
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:40am	82	0	0.0037	0	0
11:55a	81	-1	0.0037	.0037	.0148
12:10p	80	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:30p	90	0	0.0037	0	0
12:45p	90	0	0.0037	0	0
1:00pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
1:20pm	88	0	0.0037	0	0
1:35pm	87	-1	0.0037	.0037	.0148
1:50pm	87	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 11/25/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16625
Address	8498 S US 6
City	Hamlet, IN 46532
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 