

----- STATUS REPORT -----
THU AUG 08,24 5:20:03 PM
STATION NAME:
KNOLL BROS #2
8498 SUS 6635
HAMLET IN 46532

TANK 1 PRODUCT: UNLEAD REG

CURRENT STATUS:
LEAK: | | | |
GROSS: 3072.740 gal
NET: 3037.759 gal
FUEL LEVEL: 32.9101 in
H2O LEVEL: 0.0024 in
TEMP: 77.716 °F
GROSS UTF: 7061.248 gal
GROSS ULLAGE: 95%=6554.548 gal

TANK 2 PRODUCT: SUP UNLEAD

CURRENT STATUS:
GROSS: 1890.722 gal
NET: 1869.833 gal
FUEL LEVEL: 33.8322 in
H2O LEVEL: 0.0000 in
TEMP: 77.187 °F
GROSS UTF: 4114.271 gal
GROSS ULLAGE: 95%=3814.021 gal

----- MANUAL LEAK TEST -----
THU AUG 08,24 5:21:37 PM
STATION NAME:
KNOLL BROS #2
8498 SUS 6635
HAMLET IN 46532

TANK 1 PRODUCT: UNLEAD REG

LEAK RATE: 0.000 gal/hr
CANCELLED BY OPERATOR

PERCENT OF TANK TESTED: 30.3 %
START: THU AUG 08,24 5:20:27 PM
REG FUEL LEVEL: 32.9101 in
REG H2O LEVEL: 0.0025 in
REG TEMP: 77.718 °F
REG VOLUME: 3037.753 gal
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
TEMP RATE: -0.010 °F/hr
END: THU AUG 08,24 5:21:34 PM
END FUEL LEVEL: 32.9099 in
END H2O LEVEL: 0.0028 in