

oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility ID# (FID) # 16625		Contact Number
Facility Name AMAR		Contact email
Address 8498 US-6 #351A Bldg 1N		Date of Inspection 05/10/24
Operator on Duty Name 46350		Name of the Person Conducting Inspection AKSHIT SHARMA
Operator Training current ☐ Yes ☐ No		Operator Training ☐ Yes ☐ No
Is Registration current with correct owner, operator etc. ☐ Yes ☐ No		Registration/Notification Form ☐ Yes ☐ No
Release Detection Method Make and Model ECU		Release Detection ☒ ATG ☐ CIM ☐ SIR
Does it have paper? ☐ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Is it in Alarm mode? ☐ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal		Operator Notified ☐ Yes ☐ No
Necessary Monthly Printout Taken ☐ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction? ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc? ☐ Yes ☒ No		Operator Notified ☒ Yes ☐ No
Under Dispenser Containments (UDC) Are UDCs clean and free from water, debris, product etc? ☐ Yes ☒ No		Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com