

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 16625

Contact Number

Facility Name ATMCO

Contact email

Address 8498 S US HWY 6, Hamlet, WV

Date of Inspection 07/13/24

Operator on Duty Name

Y6 S32

Name of the Person Conducting Inspection AKSHIT SARAN AN.

Operator Training current

Operator Training

Yes ☐ No ☐ Operator/Notified Yes ☐ No ☐

Is Registration current with correct owner, operator etc.

Registration/Notification Form

Yes ☐ No ☐ Operator/Notified Yes ☐ No ☐

Release Detection Method

Release Detection

Yes ☒ ATG ☒ TIM ☐ SIR ☐ IC ☐ Other

Make and Model

AUTO STIR SR-2

Does it have paper?

Yes ☒ No ☐ Operator/Notified Yes ☐ No ☐

Is it in Alarm mode?

Yes ☐ No ☒ Operator/Notified Yes ☐ No ☐

Interstitial Monitoring Sensor Status Normal

Yes ☒ No ☐ Operator/Notified Yes ☐ No ☐

Necessary Monthly Printout Taken

Yes ☐ No ☐ Operator/Notified Yes ☐ No ☐

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

Yes ☐ No ☒ Operator/Notified Yes ☒ No ☐

Are the Spill Bucket in good condition and free of damage/cracks

Yes ☒ No ☐ Operator/Notified Yes ☐ No ☐

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

Yes ☒ No ☐ Operator/Notified Yes ☐ No ☐

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

Yes ☐ No ☒ Operator/Notified Yes ☒ No ☐

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

Yes ☐ No ☒ Operator/Notified Yes ☒ No ☐

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com