

----- STATUS REPORT -----
SAT JUL 13,24 4:33:57 PM
STATION NAME:
KNOLL BROS #2
8498 SUS 6635
HAMLET IN 46532

TANK 1 PRODUCT: UNLEAD REG

CURRENT STATUS:
TEST | | | | |
GROSS: 5619.826 gal
NET: 5575.252 gal
FUEL LEVEL: 52.1192 in
H2O LEVEL: 0.0058 in
TEMP: 72.300 °F
GROSS UTF: 4514.162 gal
GROSS ULLAGE: 35%=4007.462 gal

TANK 2 PRODUCT: SUP UNLEAD

CURRENT STATUS:
TEST | | | | |
GROSS: 1492.742 gal
NET: 1478.112 gal
FUEL LEVEL: 28.4925 in
H2O LEVEL: 0.0000 in
TEMP: 75.227 °F
GROSS UTF: 4512.251 gal
GROSS ULLAGE: 95%=4212.001 gal

----- MANUAL LEAK TEST -----
SAT JUL 13,24 4:34:01 PM
STATION NAME:
KNOLL BROS #2
8498 SUS 6635
HAMLET IN 46532

TANK 2 PRODUCT: SUP UNLEAD

LEAK RATE: 0.000 gal/hr
CANCELLED BY LOW VOLUME

PERCENT OF TANK TESTED: 24.8 %
START: SAT JUL 13,24 4:33:56 PM
REG FUEL LEVEL: 28.4925 in
REG H2O LEVEL: 0.0000 in
REG TEMP: 75.227 °F
REG VOLUME: 1478.112 gal
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
0.000 gal, 32.000 °F
TEMP RATE: 0.015 °F/hr
END: SAT JUL 13,24 4:34:01 PM
END FUEL LEVEL: 28.4922 in
E

.....CANCELLED BY OPERATOR.....