

ESTABROOK PRECISION LINE TEST

Facility Name: Kingsford Expo 66
 Facility Address: 8498 S US Hwy 6 Hamlet IN 46532
 Facility ID: 16625

Test Date: 10/10/2025
 Technician Name: Luke Huizenga
 Technician Cert #: 071399

Applied Pressure: 50 PSI

#1 Product Type: Regular					
TIME	DATA	-/+	GPL	RES	GPH
8:45	73	0	0.0037	0.0000	0.0000
9:00	73	0	0.0037	0.0000	0.0000
9:15	73	0	0.0037	0.0000	0.0000
FINAL RESULT: PASS					

#2 Product Type: Premium					
TIME	DATA	-/+	GPL	RES	GPH
8:45	65	0	0.0037	0.0000	0.0000
9:00	65	0	0.0037	0.0000	0.0000
9:15	65	0	0.0037	0.2405	0.9620
FINAL RESULT: PASS					

#3 Product Type: Diesel					
TIME	DATA	-/+	GPL	RES	GPH
8:45	75	0	0.0037	0.0000	0.0000
9:00	75	0	0.0037	0.0000	0.0000
9:15	75	0	0.0037	0.0000	0.0000
FINAL RESULT: PASS					

#4 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#5 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#6 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

DATA = Numbered line increments on site glass.
 -/+ = Change from previous 15-minute reading.
 GPL = Gallons per Line on site glass.
 RES = Result. Gain or loss of lines X .0037
 GPH = Gallons per Hour. RES X 4

PASS Requirements:

3 consecutive readings within .020 GPH of each other
 and final reading less than .050 GPH.

Technician Name: Luke Huizenga

Dispatch # 419772

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19