

001

30 DAYS WALK THROUGH INSPECTION

Tanks Data		Contact Number	Contact email
UST Facility I.D. (FID) #	16239		
Facility Name	Phillips 66		
Address	613 Pine Lake Ave, Lake, NV	Date of Inspection	05/10/24
Operator on Duty Name	46350	Name of the Person Conducting Inspection	AKSHIT SARHARRAN
Operator Training		Operator Training	
Operator Training current	☒ Yes ☐ No	Registration/Notification Form	☒ Yes ☐ No
Is Registration current with correct owner, operator etc.	☒ Yes ☐ No	Release Detection	☒ Yes ☐ No
Release Detection Method	☒ ATG ☐ DIM ☐ SIR ☐ IC ☐ Other	Make and Model	UR 765350
Does it have paper?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Spill Buckets		Spill Buckets	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: 317-645-0215
Signature: tanksdata@gmail.com
Date: www.tanksdata.com