



EZY CHEK SYSTEMS
LEAK DETECTOR TEST

REVISION 8/21/2019

DATE AND TIME	3/21/24 - 07:00-11:00
WEATHER	40 Cloudy
COLLECT/INVOICE	Collected
CLIENT EMAIL	-

Testing Company Information

Test Location Information		Certifications
PC # and WO #		Estabrooks: 82-1906
Name and FID #	Phillips 66 - FID 16239	ICC: 10221928
Address	613 Pine Lake Ave.	Indiana: UC 110386
City/State/Zip	LaPorte, IN 46351	CP/STI: 16655
Contact		UC111023
Phone		

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436
Technician Information	
Name	Chris Zell
Email	support@midwesttanktesting.com

TYPE OF LEAK DETECTOR - (LD) or (ELD)

PUMP #	PRODUCT	MODEL	SERIAL # (If Legible)
1	Regular	FX1V	N/A
2	Mid	FePetro	N/A
3	Premium	FePetro	N/A
4	Diesel	Suction	N/A
5			
6			
7			
8			

LEAK DETECTOR TEST

PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results
1	Regular	30	29	320	189ml	1	Pass
2	Mid	14	14	3500	189ml	65	Fail
3	Premium	37	35	370	189ml	3	Pass
4					189ml		
5					189ml		
6					189ml		
7					189ml		
8					189 ml		

COMMENTS/RECOMMENDATIONS: The mid grade leak detector after more than a min never went into operating pressure.