

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 16239

Contact Number

Facility Name Phillips 66

Contact email

Address 613 Pine Lake Ave, La Porte, IN

Date of Inspection 07/13/24

Operator on Duty Name

46350

Name of the Person
Conducting Inspection AKSHIT SHARMA

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other

Make and Model

1/2 TUS 350

Does it have paper?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports
☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS
FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com