

| Test Location Information |                         |
|---------------------------|-------------------------|
| PC # and WO #             |                         |
| Name and FID #            | Phillips 66 - FID 16239 |
| Address                   | 613 Pine Lake Ave.      |
| City/State/Zip            | LaPorte, IN 46351       |
| Contact                   |                         |
| Phone                     |                         |

| Testing Company Information |                      |
|-----------------------------|----------------------|
| Name                        | Midwest Tank Testing |
| Address                     | 316 W. Indiana Ave.  |
| City/State/Zip              | Chesterton, IN 46304 |
| Phone                       | 800-975-1436         |

| Technician Information |                                          |
|------------------------|------------------------------------------|
| Name                   | Chris Zell                               |
| Email                  | support@midwesttanktesting.com           |
| Applied Pressure       | 1-1/2 Times Working Pressure, Min 50 PSI |

**PRODUCT LINE TEST - DATA (LT)**

| #1            | Product Type: |     | Regular |         |         |
|---------------|---------------|-----|---------|---------|---------|
| TIME          | DATA          | -/+ | GPL     | RES     | GPH     |
| 7:45 AM       | 85            | 0   | 0.0037  | 0.0000  | 0.0000  |
| 8:00 AM       | 80            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:15 AM       | 75            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:30 AM       | 70            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:45 AM       | 65            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 9:00 AM       | 60            | -5  | 0.0037  | -0.0185 | -0.0740 |
| FINAL RESULT: |               |     | Fail    |         |         |

| #2            | Product Type: |     | Mid    |        |        |
|---------------|---------------|-----|--------|--------|--------|
| TIME          | DATA          | -/+ | GPL    | RES    | GPH    |
| 7:45 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| 8:00 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| 8:15 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| 8:30 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| 8:45 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| 9:00 AM       |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| FINAL RESULT: |               |     | Fail   |        |        |

| #3            | Product Type: |     | Premium |         |         |
|---------------|---------------|-----|---------|---------|---------|
| TIME          | DATA          | -/+ | GPL     | RES     | GPH     |
| 13:00         | 65            | 0   | 0.0037  | 0.0000  | 0.0000  |
| 8:00 AM       | 60            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:15 AM       | 55            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:30 AM       | 50            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 8:45 AM       | 45            | -5  | 0.0037  | -0.0185 | -0.0740 |
| 9:00 AM       | 40            | -5  | 0.0037  | -0.0185 | -0.0740 |
| FINAL RESULT: |               |     | Fail    |         |         |

| #4            | Product Type: |     |        |        |        |
|---------------|---------------|-----|--------|--------|--------|
| TIME          | DATA          | -/+ | GPL    | RES    | GPH    |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| FINAL RESULT: |               |     |        |        |        |

| #5            | Product Type: |     |        |        |        |
|---------------|---------------|-----|--------|--------|--------|
| TIME          | DATA          | -/+ | GPL    | RES    | GPH    |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| FINAL RESULT: |               |     |        |        |        |

| #6            | Product Type: |     |        |        |        |
|---------------|---------------|-----|--------|--------|--------|
| TIME          | DATA          | -/+ | GPL    | RES    | GPH    |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
|               |               | 0   | 0.0037 | 0.0000 | 0.0000 |
| FINAL RESULT: |               |     |        |        |        |

**COMMENTS/RECOMMENDATIONS:** Mid grade had air in lines and I could not get it to hold any pressure. All three shut off ball valves allow pressure to go through, so I had to use a plug to test. I had to drain liquid from prem stp area to get a plug in because liquid is above the LD. There is liquid in all of the stp areas. I talked with Roger and he said Reg and Prem are inconclusive fail because they are Tokheim stp. I left station closed via circuit breakers.



## INDIANA HOMELAND SECURITY

### Underground Storage Tank



CHRIS ZELL  
316 W INDIANA AVE  
CHESTERTON, INDIANA

STATE/PERMIT #  
UC111987

ISSUE  
12/29/2022

EFFECTIVE  
12/30/2022

EXPIRATION  
12/29/2024

#### DISCIPLINES

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal

☐ Testing

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: \_\_\_\_\_

Chris Zell

  
**Midwest Tank Testing**  
AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.  
Chesterton, IN 46304  
(800) 975-1436  
*Serving the Midwest Since 1990*