

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

JUN 8, 2024 3:05 PM

CSLD TEST RESULTS

JUN 8, 2024 3:05 PM

T 1:UNLEADED
PROBE SERIAL NUM 363263

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

T 2:UNLEADED PLUS
PROBE SERIAL NUM 363203

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

T 3:PREMIUM UNL
PROBE SERIAL NUM 333939

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

T 4:DIESEL
PROBE SERIAL NUM 511312

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

* * * * * END * * * * *

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

JUN 8, 2024 3:05 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 363263

NO TEST DATA AVAILABLE

* * * * * END * * * * *

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

JUN 8, 2024 3:05 PM

LEAK TEST REPORT

T 2:UNLEADED PLUS
PROBE SERIAL NUM 363203

NO TEST DATA AVAILABLE

* * * * * END * * * * *

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

JUN 8, 2024 3:05 PM

LEAK TEST REPORT

T 3:PREMIUM UNL
PROBE SERIAL NUM 333939

NO TEST DATA AVAILABLE

* * * * * END * * * * *

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

JUN 8, 2024 3:05 PM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 511312

NO TEST DATA AVAILABLE

* * * * * END * * * * *