



5296 Breakers Way, Carmel, IN 46033

Date 12/4/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16239
Address	613 Pine Lake Ave
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:05p	77	0	0.0037	0	0
12:20p	68	-9	0.0037	.0333	.1332
12:35p	66	-2	0.0037	.0074	.0296
12:50p	64	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Mid

TIME	DATA	+/-	GPL	RES	GPH
1:15pm	23	0	0.0037	0	0
1:30pm	19	-4	0.0037	.0148	.0592
1:45pm	17	-2	0.0037	.0074	.0296
2:00pm	15	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
2:15pm	85	0	0.0037	0	0
2:30pm	82	-3	0.0037	.0111	.0444
2:45pm	80	-2	0.0037	.0074	.0296
3:00pm	79	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 12/4/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16239
Address	613 Pine Lake Ave
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Mid	Pass
3	Premium	Pass
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 