



Date

12/4/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 16239
Address	613 Pine Lake Ave
City	La Porte, IN, 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Mid	Red Jacket MLLD		
Prem	Red Jacket MLLD		
Dies	European suction		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	24	380 ml	189ml	8 sec	Pass 
2	Mid	27	26	1000+ ml	189ml	4 sec	Pass 
3	Premium				189ml		Fail 
4					189ml		. 
5					189ml		. 
6					189ml		. 
7					189ml		. 
8					189ml		. 

Comment:

Premium line went into slow flow but never opened up afterwards. Ran test three times, never opened up.

Technician Signature :

