

TWPSERVICES, LLC
401 E 7th St
Michigan City, IN 46360
219-561-1601 / rwilloughby@twpservices.com

SITE NAME: *Phillips 66*
STREET NAME: *613 Pine Lake Ave*
CITY, STATE, ZIP: *LAPORTE IN*
DATE: *12-4-24* TIME: *10:00 AM*

OVERFILL TEST

PRODUCT	<i>Diesel</i>			
TYPE OF OVERFILL	<i>7/150</i>			
TANK SIZE	<i>2K</i>			
TANK DIAMETER	<i>64</i>			
MECHANISM MOVES FREELY?	<i>Yes -</i>			
RISER LENGTH	<i>43</i>			
TOP OF RISER TO OVERFILL	<i>55</i>			
OVERFILL FROM TANK BOTTOM				
OVERFILL SET @90%	<i>Yes -</i>			
RESULT	<i>PASS -</i>			