

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (EID) #	162239	Contact Number	
Facility Name	WILDE 66	Contact email	
Address	613 Pine Lake Ave	Date of Inspection	03-12-25
Operator on Duty Name	LaRocca, IN-46350	Name of the Person Conducting Inspection	ANKIT

Operator Training		Registration/Notification Form		Release Detection	
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Release Detection Method	☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Make and Model	
		Operator Notified	☐ Yes ☐ No	Does it have paper?	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Is it in Alarm mode?	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Necessary Monthly Printout Taken	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Spill Buckets	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Under Dispenser Containments (UDC)	☒ Yes ☐ No
		Operator Notified	☐ Yes ☐ No	Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com