

RUSH HOUR
613 PINELAKE AVE
LA PORTE IN 46530

MAR 7, 2025 5:36 PM

CSLD TEST RESULTS

MAR 7, 2025 5:36 PM

T 1:UNLEADED
PROBE SERIAL NUM 363263

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 2:UNLEADED PLUS
PROBE SERIAL NUM 363203

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 3:PREMIUM UNL
PROBE SERIAL NUM 333939

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 511312

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

***** END *****

LEAK TEST STATUS:
TEST NOT IN PROGRESS

RUSH HOUR

613 PINELAKE AVE

LA PORTE IN 46530

MAR 7, 2025 5:36 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 363263

NO TEST DATA AVAILABLE

***** END *****

RUSH HOUR

613 PINELAKE AVE

LA PORTE IN 46530

MAR 7, 2025 5:36 PM

LEAK TEST REPORT

T 2:UNLEADED PLUS
PROBE SERIAL NUM 363203

NO TEST DATA AVAILABLE

***** END *****

RUSH HOUR

613 PINELAKE AVE

LA PORTE IN 46530

MAR 7, 2025 5:36 PM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 511312

NO TEST DATA AVAILABLE

***** END *****