



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 2/25/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 16239
Address	613 Pine Lake Ave
City	La Porte,IN 46350
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Mid	Red Jacket MLLD		
Prem	Red Jacket MLLD		
Dies	European suction		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular				189ml	.	v
2	Mid				189ml	.	v
3	Premium	26	25	290 ml	189ml	3 sec	Pass v
4					189ml	.	v
5					189ml	.	v
6					189ml	.	v
7					189ml	.	v
8					189ml	.	v

Comment:

Other two lines were tested on first visit. The premium line was a retest.

Technician Signature :

