

P&L EXPO
4005 Western Ave
South Bend, IN
USA

12/20/2024 17:31:19

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED

UNLEADED

Capacity: 11,608.0

Begin End

12/14/2024 12/19/2024

05:39:45 08:24:50

Result Pass

Slope 0.04

Status 0

Volume Qualify % >= 14

PREMIUM

PREMIUM

Capacity: 2,824.0

Begin End

12/20/2024 12/20/2024

12:15:22 13:40:29

Result Pass

Slope 0.00

Status 0

Volume Qualify % >= 14

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

12/20/2024 17:31:25

REGULATORY REPORT

(Passed Tests)

December 2024

units:gph

TANKS (MONTHLY)

Tank 1

UNLEADED

SCALD

Slope 0.04

▶ 12/14/2024 05:39:45

▶ 12/19/2024 08:24:50

Volume Qualify % >= 14

Slope -0.04

▶ 12/07/2024 00:28:38

▶ 12/07/2024 05:06:19

Volume Qualify % >= 14

Tank 2

PREMIUM

SCALD

Slope 0.00

▶ 12/20/2024 12:15:22

▶ 12/20/2024 13:40:29

Volume Qualify % >= 14

Slope -0.02

▶ 12/17/2024 00:29:58

▶ 12/17/2024 02:30:39

Volume Qualify % ---

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP

12/20/2024 12:00:00

PREM STP SUMP

12/20/2024 12:00:00

12/02/2024 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE

12/20/2024 12:00:00

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

12/20/2024 17:31:26

SENSOR REPORT

Last Available

2 WIRE SENSOR

UNL STP SUMP

OK

12/20/2024 17:31:26

PREM STP SUMP

OK

12/20/2024 17:31:26

3 WIRE SENSOR

TANK INTERSTICE

OK

12/20/2024 17:31:26

MAG SENSOR

No P...