

P&L EXPO
4005 Western Ave
South Bend, IN
USA
08/07/2024 16:52:22
SCALO REPORT
Last Available
units:gal, in, °F

TANKS

UNLEADED
UNLEADED Capacity: 11,600.0
Begin 08/06/2024 02:44:46
End 08/07/2024 03:21:52
Result -0.07
Slope 0
Status
Volume Qualify % >= 14

PREMIUM
PREMIUM Capacity: 2,024.0
Begin 08/07/2024 13:31:55
End 08/07/2024 15:13:44
Result -0.03
Slope 0
Status
Volume Qualify % >= 14

.....
P&L EXPO
4005 Western Ave
South Bend, IN
USA
08/07/2024 16:52:23
REGULATORY REPORT
(Passed Tests)
August 2024

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALO Slope -0.07
08/06/2024 02:44:46
08/07/2024 03:21:52
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALO Slope -0.03
08/07/2024 13:31:55
08/07/2024 15:13:44
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
08/07/2024 12:00:00
08/06/2024 12:00:00

PREM STP SUMP
08/07/2024 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
08/07/2024 12:00:00
08/06/2024 12:00:00

.....
P&L EXPO
4005 Western Ave
South Bend, IN
USA
08/07/2024 16:52:24

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP
Ok
08/07/2024 16:52:24

PREM STP SUMP
Ok
08/07/2024 16:52:24

3 WIRE SENSOR

TANK INTERSTICE
Ok
08/07/2024 16:52:24

MAG SENSOR