

P&L EXPO
4005 Western Ave
South Bend, IN
USA
10/18/2024 13:39:21

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,600.0

Begin	End
10/17/2024 08:56:45	10/17/2024 22:50:12
Result	Pass
Slope	0.05
Status	0
Volume Qualify %	>= 14

PREMIUM
PREMIUM
Capacity: 2,824.0

Begin	End
10/18/2024 05:55:23	10/18/2024 07:37:28
Result	Pass
Slope	-0.02
Status	0
Volume Qualify %	>= 14

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
10/18/2024 13:39:22

REGULATORY REPORT
(Passed Tests)
October 2024

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope 0.05
▶ 10/17/2024 08:56:45
▶ 10/17/2024 22:50:12
Volume Qualify % >= 14
Slope -0.04
▶ 10/09/2024 00:54:48
▶ 10/09/2024 03:58:43
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.02
▶ 10/18/2024 05:55:23
▶ 10/18/2024 07:37:28
Volume Qualify % >= 14
Slope 0.01
▶ 10/18/2024 03:04:39
▶ 10/18/2024 04:29:56
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
10/18/2024 12:00:00
10/03/2024 12:00:00

PREM STP SUMP
10/18/2024 12:00:00
10/05/2024 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
10/18/2024 12:00:00
10/03/2024 12:00:00

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
10/18/2024 13:39:28

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP
OK
10/18/2024 13:39:28

PREM STP SUMP
OK
10/18/2024 13:39:28

3 WIRE SENSOR

TANK INTERSTICE
OK
10/18/2024 13:39:28

MAG SENSOR

No Records Found