

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	15454	Contact Number	
Facility Name	Phillips 66	Contact email	
Address	40050 Western Ave, Seattle	Date of Inspection	09/05/12
Operator on Duty Name	Bruna, W 76619	Name of the Person Conducting Inspection	AKSHIT
Operator Training			
Operator Training current	☐ Yes ☐ No	Registration/Notification Form	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Release Detection	☐ Yes ☐ No
Release Detection Method	ATG	Release Detection	ATG
Make and Model	FFS TSEU0550	Release Detection	FFS TSEU0550
Does it have paper?	☒ Yes ☐ No	Release Detection	FFS TSEU0550
Is it in Alarm mode?	☒ Yes ☐ No	Release Detection	FFS TSEU0550
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Release Detection	FFS TSEU0550
Necessary Monthly Printout Taken	☒ Yes ☐ No	Release Detection	FFS TSEU0550
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Under Dispenser Contaminants (UDC)	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified	☐ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name		Signature	
317-645-0215		Date	
tanksdata@gmail.com		www.tanksdata.com	