

P&L EXPO
4005 Western Ave
South Bend, IN
USA
07/05/2024 17:11:10
SCALD REPORT
Last Available
units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0
Begin End
07/02/2024 07/03/2024
06:20:04 22:18:26
Result Pass
Slope -0.07
Status 0
Volume Qualify % >= 14
PREMIUM
PREMIUM
Capacity: 2,824.0
Begin End
07/05/2024 07/05/2024
08:48:21 13:47:07
Result Pass
Slope -0.03
Status 0
Volume Qualify % >= 14
.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
07/05/2024 17:11:11
REGULATORY REPORT
(Passed Tests)
July 2024
units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.07
▶ 07/02/2024 06:20:04
▶ 07/03/2024 22:18:26
Volume Qualify % >= 14
Tank 2
PREMIUM
SCALD
Slope -0.03
▶ 07/05/2024 08:48:21
▶ 07/05/2024 13:47:07
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
07/05/2024 12:00:00
PREM STP SUMP
07/05/2024 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
07/05/2024 12:00:00
.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
07/05/2024 17:11:16
SENSOR REPORT
Last Available
2 WIRE SENSOR

UNL STP SUMP
Ok
07/05/2024 17:11:16
PREM STP SUMP
Ok
07/05/2024 17:11:16

3 WIRE SENSOR

TANK INTERSTICE
Ok
07/05/2024 17:11:16

MAG SENSOR