

P&L EXPO
4005 Western Ave
South Bend, IN
USA
06/03/2024 16:22:44
SCALD REPORT
Last Available
units:gal, in, °F

TANKS
UNLEADED
UNLEADED
Capacity: 11,608.0
Begin End
06/02/2024 06/02/2024
06:16:35 09:23:12
Result Pass
Slope -0.08
Status 0
Volume Qualify % >= 14
PREMIUM
PREMIUM
Capacity: 2,824.0
Begin End
06/03/2024 06/03/2024
10:37:27 12:32:13
Result Pass
Slope 0.01
Status 0
Volume Qualify % >= 14

P&L EXPO
4005 Western Ave
South Bend, IN
USA
06/03/2024 16:22:45
REGULATORY REPORT
(Passed Tests)
June 2024
units:gph

TANKS (MONTHLY)
Tank 1
UNLEADED
SCALD
Slope -0.08
▶ 06/02/2024 06:16:35
▶ 06/02/2024 09:23:12
Volume Qualify % >= 14
Tank 2
PREMIUM
SCALD
Slope 0.01
▶ 06/03/2024 10:37:27
▶ 06/03/2024 12:32:13
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)
UNL STP SUMP
06/03/2024 12:00:00
PREM STP SUMP
06/03/2024 12:00:00

3 WIRE SENSOR (MONTHLY)
TANK INTERSTICE
06/03/2024 12:00:00

P&L EXPO
4005 Western Ave
South Bend, IN
USA
06/03/2024 16:22:50
SENSOR REPORT
Last Available
2 WIRE SENSOR

UNL STP SUMP
Ok
06/03/2024 16:22:51
PREM STP SUMP
Ok
06/03/2024 16:22:51

3 WIRE SENSOR
TANK INTERSTICE
Ok
06/03/2024 16:22:51

MAG SENSOR

No Records Found