

P&L EXPO
4005 Western Ave
South Bend, IN
USA
01/24/2025 12:24:27

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED

UNLEADED

Capacity: 11,608.0

Begin End

01/21/2025 01/21/2025

01:53:54 05:47:23

Result Pass

Slope -0.08

Status 0

Volume Qualify % >= 14

PREMIUM

PREMIUM

Capacity: 2,824.0

Begin End

01/20/2025 01/20/2025

11:03:35 12:41:14

Result Pass

Slope -0.05

Status 0

Volume Qualify % >= 14

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
01/24/2025 12:24:32

REGULATORY REPORT
(Passed Tests)
January 2025

units:gph

TANKS (MONTHLY)

Tank 1

UNLEADED

SCALD

Slope -0.08

▶ 01/21/2025 01:53:54

▶ 01/21/2025 05:47:23

Volume Qualify % >= 14

Slope -0.04

▶ 01/01/2025 03:37:10

▶ 01/01/2025 09:49:35

Volume Qualify % >= 14

Tank 2
PREMIUM
Static
Slope -0.04
▶ 01/24/2025 00:29:59
▶ 01/24/2025 02:30:35
Volume Qualify % ---
Slope -0.00
▶ 01/16/2025 00:30:00
▶ 01/16/2025 02:30:36
Volume Qualify % ---

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
01/24/2025 12:00:00

PREM STP SUMP
01/24/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
01/24/2025 12:00:00

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
01/24/2025 12:24:33

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP
OK
01/24/2025 12:24:33

PREM STP SUMP
OK
01/24/2025 12:24:33

3 WIRE SENSOR

TANK INTERSTICE
OK
01/24/2025 12:24:33

MAG SENSOR

No Records Found