



Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	18454	Contact Number	
Facility Name	Phillips	Contact email	
Address	900 S Western Ave, South Leech	Date of Inspection	04-26-25
Operator on Duty Name	JN-46619	Name of the Person Conducting Inspection	Moham Singh

Operator Training current	Operator Training	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	Release Detection	☒ ATG ☐ CIM	☐ SIR ☐ IC ☐ Other	
Make and Model				
Does it have paper?		☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?		☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal		☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken		☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	Spill Buckets	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks		☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Fill Ports	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	Piping/STP Sumps	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	Under Dispenser Containments (UDC)	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

Date

tanksdata@gmail.com

www.tanksdata.com

20220516