

P&L EXPO
4005 Western Ave
South Bend, IN
USA
06/27/2025 16:56:13

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11,608.0

Begin	End
06/25/2025 19:45:16	06/26/2025 01:45:27
Result	Pass
Slope	0.02
Status	0
Volume Qualify %	>= 14

PREMIUM
PREMIUM
Capacity: 2,824.0

Begin	End
06/27/2025 13:42:11	06/27/2025 15:30:29
Result	Pass
Slope	0.05
Status	0
Volume Qualify %	>= 14

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA
06/27/2025 16:56:19

REGULATORY REPORT
(Passed Tests)
June 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope 0.02
▶ 06/25/2025 19:45:16
▶ 06/26/2025 01:45:27
Volume Qualify % >= 14
Slope -0.06
▶ 06/23/2025 13:13:18
▶ 06/24/2025 02:25:58
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope 0.05
▶ 06/27/2025 13:42:11
▶ 06/27/2025 15:30:29
Volume Qualify % >= 14
Slope 0.00
▶ 06/12/2025 06:09:24
▶ 06/12/2025 08:23:00
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
06/27/2025 12:00:00
06/22/2025 12:00:00

PREM STP SUMP
06/27/2025 12:00:00
06/24/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
06/27/2025 12:00:00
06/22/2025 12:00:00

.....