

P&L EXPO  
4005 Western Ave  
South Bend, IN  
USA  
03/21/2025 20:31:16

SCALD REPORT  
Last Available

units:gal, in, °F

TANKS

UNLEADED  
UNLEADED  
Capacity: 11,608.0  
Begin End  
03/21/2025 03/21/2025  
01:09:18 03:56:48  
Result Pass  
Slope -0.05  
Status 0  
Volume Qualify % >= 14

PREMIUM  
PREMIUM  
Capacity: 2,824.0  
Begin End  
03/17/2025 03/17/2025  
10:03:18 11:39:45  
Result Pass  
Slope -0.07  
Status 0  
Volume Qualify % >= 14

.....

P&L EXPO  
4005 Western Ave  
South Bend, IN  
USA  
03/21/2025 20:31:31

REGULATORY REPORT  
(Passed Tests)  
March 2025

units:gph

TANKS (MONTHLY)

Tank 1  
UNLEADED  
SCALD  
Slope -0.05  
▶ 03/21/2025 01:09:18  
▶ 03/21/2025 03:56:48  
Volume Qualify % >= 14

Tank 2  
PREMIUM  
SCALD  
Slope -0.07  
▶ 03/17/2025 10:03:18  
▶ 03/17/2025 11:39:45  
Volume Qualify % >= 14  
Slope -0.03  
▶ 03/14/2025 08:55:39  
▶ 03/14/2025 10:27:32  
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP  
03/21/2025 12:00:00

PREM STP SUMP  
03/21/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE  
03/21/2025 12:00:00

.....

P&L EXPO  
4005 Western Ave  
South Bend, IN  
USA  
03/21/2025 20:31:37

SENSOR REPORT  
Last Available

2 WIRE SENSOR

UNL STP SUMP  
Ok  
03/21/2025 20:31:37

PREM STP SUMP