

P&L EXPO
4005 Western Ave
South Bend, IN
USA

04/26/2025 15:27:38

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED

Capacity 11,608.0

Begin	End
04/26/2025 00:29:57	04/26/2025 00:30:02
-----Gross-----	
5,265.0	5,264.8
-----Water Level-----	
0.76	0.76
-----Water Volume-----	
18.2	18.2
-----Net-----	
5,297.6	5,297.4
-----Level-----	
42.09	42.09
-----Temperature-----	
51.16	51.16

Last Delivery
04/22/2025 09:55:46
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 45.35

PREMIUM
PREMIUM
Capacity 2,824.0

Begin	End
04/26/2025 00:30:00	04/26/2025 00:30:04
-----Gross-----	
1,522.2	1,522.2
-----Water Level-----	
0.78	0.78
-----Water Volume-----	
5.7	5.7
-----Net-----	
1,530.3	1,530.3
-----Level-----	
48.14	48.14
-----Temperature-----	
52.33	52.33

Last Delivery
04/17/2025 08:01:58
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 53.90

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

04/26/2025 15:27:44

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED

Capacity: 11,608.0

Begin	End
04/26/2025 04:48:16	04/26/2025 07:15:12
Result	Pass
Slope	-0.03
Status	0
Volume Qualify %	>= 14

PREMIUM
PREMIUM
Capacity: 2,824.0

Begin	End
04/26/2025 12:19:15	04/26/2025 13:52:42
Result	Pass
Slope	-0.04
Status	0
Volume Qualify %	>= 14

P&L EXPO
4005 Western Ave
South Bend, IN
USA
04/26/2025 15:27:50

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP
Ok
04/26/2025 15:27:50

PREM STP SUMP
Ok
04/26/2025 15:27:50

3 WIRE SENSOR

TANK INTERSTICE
Ok
04/26/2025 15:27:50

MAG SENSOR

No Records Found

P&L EXPO
4005 Western Ave
South Bend, IN
USA
04/26/2025 15:27:50

REGULATORY REPORT
(Passed Tests)
April 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.03
▶ 04/26/2025 04:48:16
▶ 04/26/2025 07:15:12
Volume Qualify % >= 14
Slope -0.09
▶ 04/25/2025 19:49:17
▶ 04/26/2025 03:12:52
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope -0.04
▶ 04/26/2025 12:19:15
▶ 04/26/2025 13:52:42
Volume Qualify % >= 14
Slope 0.01
▶ 04/13/2025 08:09:39
▶ 04/13/2025 09:34:56
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
04/26/2025 12:00:00
04/25/2025 12:00:00

PREM STP SUMP
04/26/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE
04/26/2025 12:00:00
04/25/2025 12:00:00