



5296 Breakers Way, Carmel, IN 46033

Date

4/8/25

PRODUCT LINE TEST

Test Location Information

Name	FID 15454
Address	4005 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1	Product Type : Regular				
TIME	DATA	+/-	GPL	RES	GPH
12:50p	90	0	0.0037	0	0
1:05pm	90	0	0.0037	0	0
1:20pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2	Product Type : Premium				
TIME	DATA	+/-	GPL	RES	GPH
1:40pm	90	0	0.0037	0	0
1:55pm	90	0	0.0037	0	0
2:10pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3	Product Type :				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4	Product Type :				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 4/8/25

PRODUCT LINE TEST

Test Location Information

Name	FID 15454
Address	4005 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 