

TRIENNIAL INSPECTION

Facility Name: PHILLIPS 66 -SOUTH BEND
Facility Address: 4005 W WESTERN AVE SOUTH BEND IN ...
Facility ID: 15454

Test Date: 10/28/2025

UST CONTAINMENT SUMP INTEGRITY TESTING: HYDROSTATIC

Test Type/Reason: Triennial

Sump Name	Reg stp	Premium stp	1/2	3/4	5/6
Clean of liquid/debris	YES	YES	YES	YES	YES
VISUAL INSPECTION	PASS	PASS	PASS	PASS	PASS
Test Start Time	9:00	9:00	9:00	9:00	9:00
Test End Time	10:00	10:00	10:00	10:00	10:00
Starting Water Level (in)	24	24	20	20	20
Ending Water Level (in)	24	24	20	20	20
Water Level Change (in)	0	0	0	0	0
TEST RESULT	PASS	PASS	PASS	PASS	PASS

Sump Name					
Clean of liquid/debris					
VISUAL INSPECTION					
Test Start Time					
Test End Time					
Starting Water Level (in)					
Ending Water Level (in)					
Water Level Change (in)					
TEST RESULT					

Comments

--

Technician Name: Dan Groen

Dispatch # 420526

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19