

P&L EXPO
4005 Western Ave
South Bend, IN
USA

02/23/2025 18:05:58

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

UNLEADED
UNLEADED
Capacity: 11.608.0

Begin End
02/19/2025 02/19/2025
03:46:15 11:50:01

Result Pass

Slope -0.10

Status 0

Volume Qualify % >= 14

PREMIUM
PREMIUM
Capacity: 2.824.0

Begin End
02/19/2025 02/23/2025
11:08:08 13:27:54

Result Pass

Slope -0.04

Status 0

Volume Qualify % >= 14

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

02/23/2025 18:06:04

REGULATORY REPORT
(Passed Tests)
February 2025

units:gph

TANKS (MONTHLY)

Tank 1

UNLEADED

SCALD

Slope -0.10

▶ 02/19/2025 03:46:15

▶ 02/19/2025 11:50:01

Volume Qualify % >= 14

Tank 2

PREMIUM

SCALD

Slope -0.04

▶ 02/19/2025 11:08:08

▶ 02/23/2025 13:27:54

Volume Qualify % >= 14

Slope -0.06

▶ 02/12/2025 08:44:18

▶ 02/12/2025 10:43:38

Volume Qualify % >= 14

.....

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP

02/23/2025 12:00:00

PREM STP SUMP

02/23/2025 12:00:00

.....

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE

02/23/2025 12:00:00

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

02/23/2025 18:06:04

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP

OK

02/23/2025 18:06:04

PREM STP SUMP

OK

02/23/2025 18:06:04

.....

3 WIRE SENSOR

TANK INTERSTICE

OK

02/23/2025 18:06:04

MAG SENSOR

No Records Found