



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

4/8/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 15454
Address	4005 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	26	140 ml	189ml	2 sec	Pass 
2	Premium	27	27	120 ml	189ml	2 sec	Pass 
3					189ml		. 
4					189ml		. 
5					189ml		. 
6					189ml		. 
7					189ml		. 
8					189ml		. 

Comment:

Technician Signature :

