

P&L EXPO
4005 Western Ave
South Bend, IN
USA

08/26/2025 17:45:46

REGULATORY REPORT
(Passed Tests)
August 2025

units:gph

TANKS (MONTHLY)

Tank 1
UNLEADED
SCALD
Slope -0.07
▶ 08/26/2025 03:40:04
▶ 08/26/2025 11:41:56
Volume Qualify % >= 14
Slope -0.08
▶ 08/22/2025 03:06:32
▶ 08/22/2025 09:38:38
Volume Qualify % >= 14

Tank 2
PREMIUM
SCALD
Slope 0.03
▶ 08/26/2025 10:52:41
▶ 08/26/2025 12:19:42
Volume Qualify % >= 14
Slope 0.03
▶ 08/10/2025 16:19:39
▶ 08/11/2025 05:14:20
Volume Qualify % >= 14

2 WIRE SENSOR (MONTHLY)

UNL STP SUMP
08/26/2025 12:00:00
08/19/2025 12:00:00

PREM STP SUMP
08/26/2025 12:00:00
08/21/2025 12:00:00

3 WIRE SENSOR (MONTHLY)

TANK INTERSTICE

08/26/2025 12:00:00

08/19/2025 12:00:00

.....

P&L EXPO
4005 Western Ave
South Bend, IN
USA

08/26/2025 17:45:52

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP SUMP

OK

08/26/2025 17:45:52

PREM STP SUMP

OK

08/26/2025 17:45:52

3 WIRE SENSOR

TANK INTERSTICE

OK

08/26/2025 17:45:52

MAG SENSOR

No Records Found