

TRIENNIAL INSPECTION

Facility Name: PL EXPO FOOD

Test Date: 03/27/2025

Facility Address: 4005 W WESTERN AVE SOUTH BEND IN ...

Facility ID: 15454

UST CONTAINMENT SUMP INTEGRITY TESTING: HYDROSTATIC

Test Type/Reason: Triennial

Sump Name	1/2	3/4	5/6		
Clean of liquid/debris	YES	YES	YES		
VISUAL INSPECTION	PASS	PASS	PASS		
Test Start Time	9:40	9:40	9:40		
Test End Time	10:40	10:40	10:40		
Starting Water Level (in)	18	15	17		
Ending Water Level (in)	18	15	17		
Water Level Change (in)	0	0	0		
TEST RESULT	PASS	PASS	PASS		

Sump Name					
Clean of liquid/debris					
VISUAL INSPECTION					
Test Start Time					
Test End Time					
Starting Water Level (in)					
Ending Water Level (in)					
Water Level Change (in)					
TEST RESULT					

Comments

--

Technician Name: Blake D. Zylstra

Dispatch # 7578

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19