B&K EQUIPMENT
www.bkequip.com

2939 175th ST.
Lansing, IL 60438
708-474-3344

TRIENNIAL INSPECTION

Facility Name: PL EXPO FOOD Test Date: 03/27/2025
Facility Address: 4005 W WESTERN AVE SOUTH BEND IN 46619
Facility ID: 15454

OVERFILL PREVENTION EQUIPMENT INSPECTION

Tank ID #	T1	T2				
Product	Rul	Pul				
Tank Volume (gallons)	11608	2824				
Tank Diameter (Inches)	90.5	90.5				
Calculated 90% Level (Inches)	76	76.5				
Calculated 95% Level (Inches)	80.5	80.5				

Automatic Shutoff Device (Flapper Valve) Inspection

Measured Shutoff Level (Inches)	80.5	80.5				
Drop tube removed from tank?	YES	YES				
Drop tube and float mechanism free of debris?	YES	YES				
Float moves freely and poppet moves into flow path?	YES	YES				
Bypass valve in drop tube open and unblocked?	N/A	N/A				
Flapper valve adjusted to shut off flow at what % of tank capacity?	95	95				
INSPECTION RESULT	PASS	PASS				

Overfill Alarm Inspection

Electronic device and probe operating properly?						
Alarm activates at 90% of tank capacity?						
Alarm is heard and seen from tank fueling area?						
INSPECTION RESULT						

Comments

No ball floats were present. Drop tube set to 95%

Technician Name: Luke Huizenga
Dispatch # 7578
B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19