

Handy Shot
2701 Prairie Ave
Elmhurst, IL 60120
12/23 1:20 PM
SOLO TEST REPORT
10140.0 GAL
UNLEAD

TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
VOL. CAP. 10.0
VOL. CAP. 10.0
TESTED 31.12 PM
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.84 GAL/H
ULT. PASSED
SLOPE ERROR 0.000

DIESEL 0.000 H
PREMIUM
LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.99%
GROSS CAPACITY 10.0
NET 0.00
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT PASSED
REASON CALCULATED
LEAK RATE

LEAK 10140.0 GAL
DELE
TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
VOL. CAP. 10.0
VOL. CAP. 10.0
TESTED 31.04 PM
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.006 GAL/H
RESULT PASSED
REASON 0.000
NOTE

Handy Shot
2701 Prairie Ave
Elmhurst, IL 60120
12/23 1:21 PM
LEAK TEST REPORT
UNLEAD

LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.99%
GROSS CAPACITY 10.0
NET 0.00
TESTED 31.12 PM
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT PASSED
REASON CALCULATED
LEAK RATE

TEST 0.200 GPH
CONFIDENCE LEVEL 99.99%
GROSS CAPACITY 10.0
NET 0.00
TESTED 31.12 PM
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT PASSED
REASON CALCULATED
LEAK RATE

PREMIUM
LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 99.99%
GROSS CAPACITY 10.0
NET 0.00
TESTED 31.12 PM
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT PASSED
REASON CALCULATED
LEAK RATE

Handy Shot
2701 Prairie Ave
Elmhurst, IL 60120
12/23/2023 1:22 PM

LEAK TEST REPORT
UNLEAD 10140.0 GAL

UNLEAD
END TIME 21:00 PM
DATE 12/23/2023
RESULT ABORTED
REASON 0.000

LEAK 10140.0 GAL

PREMIUM
TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.99%
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT INCOMPLETE
REASON 0.000

LEAK 10140.0 GAL

DIESEL
LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 99.99%
TEST STARTED 12/23/2023
TEST ENDED 12/23/2023
SLOPE -0.037 GAL/H
TEST RESULT INCOMPLETE
REASON 0.000

Handy Shot
2701 Prairie Ave
Elmhurst, IL 60120
12/23/2023 1:23 PM

REGULATOR REPORT
HARDWARE STATUS

TS-CM 0.000 H
TS-CM 0.000 H